Analytical Data of Water Samples Submitted By Sri. Ramesh Gardas, Chief Executive Officer, Suzuion Technologies Pvt. Ltd, during the month of July - 2020.

Sl.No	*Lab No*	Village/Location	*pH at 25 °C*	*Sp cond at 25°C mic.Sie / cm.*	*TDS Calculated mg/lit.*	Na^+ mg/l.	K^+ mg/l.	Ca mg/l.	Mg^{2+} mg/l.	CO_3^{-2} as $CaCO_3$ mg/l.	HCO_3^- as $CaCo_3$ mg/l.	Cl^- mg/l.	SO_4^{-2} mg/l.	Nitrate mg/l.	F^- mg/l.	T.H. as $CaCO_3$ mg/lit.
BIS Permissible limits			6.50 to 8.50	< 750=Good 750 to 1500=Safe 1500 to 3000 Permissible >3000 U.S.	500-2000	No Guidelines	No Guidelines	75-200	30-100	200-600	200-600	250-1000	200-400	45	1.0-1.5	200-600
1	2	3	5	6	7	8	9	10	11	12	13	14	15	16	17	18
1	42	Sample-1	8.70	406	260	36	2	40	5	20	80	60	13	1	0.30	120

Disclaimer: The analytical data given is subject to the condition of sampling and method of collection and submission to the lab.

The temperature at which pH determined is the temperature of the samples.

Sd/- Director

/// True Copy///

Assistant Director (WA)